

NSF International

789 N. Dixboro Road, Ann Arbor, MI 48105 USA

RECOGNIZES

CERAFILTEC Germany GmbH Blue Filtration


Facility: St. Ingbert, Germany

AS COMPLYING WITH NSF/ANSI/CAN 61 AND ALL APPLICABLE REQUIREMENTS.
PRODUCTS APPEARING IN THE NSF OFFICIAL LISTING ARE
AUTHORIZED TO BEAR THE NSF MARK.



ISO/IEC 17065
Product Certification Body
#0216

Certification Program
Accredited by the
American National
Standards Institute



Certification Program
Accredited by the
Standards Council
of Canada

This certificate is the property of NSF International and must be returned upon request. This certificate remains valid as long as this client has products in Listing for the referenced standards. For the most current and complete Listing information, please access NSF's website (www.nsi.org).

A handwritten signature in black ink, appearing to read "David Purkiss", is written over a horizontal line.

July 30, 2021

Certificate# C0584425 - 01

David Purkiss

Vice President, Global Water Division



OFFICIAL LISTING

NSF certifies that the products appearing on this Listing conform to the requirements of
NSF/ANSI/CAN 61 - Drinking Water System Components - Health Effects

This is the Official Listing recorded on August 19, 2021.

CERAFILTEC Germany GmbH Blue Filtration
Science Park 2
Saarbrücken
66123
Germany
49 681 93587 089

Facility: St. Ingbert, Germany

Mechanical Devices

Trade Designation	Size	Water Contact Temp	Water Contact Material
Filtration Devices / Components			
Base Set	[1]	D. HOT	MLTPL
Header Set	[1]	D. HOT	MLTPL
Module 6.0 S - S1	[1]	D. HOT	MLTPL
S1 Ceramic Plate	[1]	D. HOT	MLTPL

- [1] Module 6.0 S, the Header Set, and the Base Set are certified for a minimum flow of 14,000 liters per day.
The S1 Ceramic Plate is certified for a minimum flow of 348 liters per day.
The Header Set, Base Set, and S1 Ceramic Plate spare parts are to be used with the Module 6.0 S only.
The S1 Ceramic plate requires a 0.5 liters per minute flush for ten (10) minutes with tap water before use.
The Module 6.0 S, Header Set, and Base Set all requires a 10 liters per minute flush for ten (10) minutes with tap water before use.
Certified for use with a 384 L tank or greater.

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF.

1 of 1

OFFICIAL LISTING ONLINE



<https://info.nsf.org/Certified/PwsComponents/Listings.asp?Company=C0584424&Standard=061>